

APPENDIX B - RTO414164 - Price Schedule - Water Bus Main Refurbishment

Item No.	Description	Unit	Rate(UGX)	Amount(UGX)
1	Fabricate and supply the pipes, bends, T-joints and flanges as per the specifications given and/or according to confirmatory measurements taken on site.	Lump sum		
2	Clean and paint the new fabricated pipeline using Interseal 670HS Green; DFT -200-400microns	Lump sum		
3	Dismantle, service and do repairs on the isolation valves	Lump sum		
4	Dismantle the existing water pipeline that connects the spiral casing refilling line to the water bus main.	Lump sum		
5	Fit/join by welding the T-joint, 90° bend and straight pipe for replacement and erect the new pipeline	Lump sum		
6	Do NDT on the welded joints to check for cracks and flaws. If cracks are detected, redo the weld. Check and correct any form of misalignment of the installed pipework deviating from the existing parent pipeline network	Lump sum		
7	Mobilize, Demobilize and clear site. The Contractor shall make good all damaged areas	Lump sum		
8	Provisional sum/contingency (5%)			
SUB-TOTAL (excluding VAT and Taxes)				

Pricing Notes:

Currency: All quoted amounts must be in Ugandan Shillings (UGX) for local companies and in USD for Overseas Companies

Delivery Period: Supplier to indicate the best service execution duration.

Warranty:

Incoterms:

EUL's preferred Incoterms are DAP Nalubaale Power Station, for Overseas Companies and DDP Nalubaale Power Station for local Companies.

Payment Terms:

Defects Period:

Retention:

Performance Bond: The Tenderer must express willingness to post 10% performance Bond of the tendered and contracted value of the services offered. This bond will be used to pay for the Tender's failure to complete the services under this contract.

Day-work Rates/hourly Rates should be submitted where applicable

PRICE BASE:

Prices quoted by the Bidder shall be fixed during the Bidder's performance of the Contract and not subject to variation on any account, unless otherwise specified in the Bid documents. A bid submitted with an adjustable price quotation shall be treated as non-responsive and shall be rejected. However, if in accordance with the Bids Documents, prices quoted by the Bidder shall be subject to adjustment during the performance of the Contract, a bid submitted with a fixed price quotation shall not be rejected, but the price adjustment shall be treated as zero.

Note: that all foreign services offered within Uganda attract a With-Holding Tax. Therefore the bidder must state clearly what sort of taxes is excluded from their price.